



- NOTES:-**
- 1) ALL DIMENSIONS ARE IN m.m.
 - 2) CONCRETE MIX M-25 CONFORMING TO IS:456-2000, SHALL BE USED UNLESS SPECIFIED OTHERWISE.
 - 3) CLEAR COVER TO REINFORCEMENT SHALL BE 50 mm.
 - 4) CONCRETE SHALL BE MACHINE MIXED, MACHINE VIBRATED AND SHALL BE CONSTANTLY WET FOR SEVEN DAYS AFTER DATE OF PLACING.
 - 5) # INDICATES HIGH YIELD STRENGTH DEFORMED BARS, Fe - 500, CONFORMING TO IS:1786-1985 OR EQUIVALENT.
 - 6) DIMENSIONS ARE TO BE READ AND NOT MEASURED.
 - 7) ALL LEVELS AND DIMENSIONS MENTIONED IN THE DRAWING ARE FINISHED LEVELS AND DIMENSIONS.
 - 8) BASE SLAB IS TO BE ANCHORED WITH THE ROCK AS SHOWN IN DRG. NO. 563.1
 - 9) OTHER SPECIFICATIONS SHALL BE AS PER THE TENDER DOCUMENTS.

REV. NO.	REV. DATE	REVISION DETAILS	APPD. BY

PRINCIPAL CLIENT :-

ARCHITECT:-

PROJECT TITLE:-

DRG. NO.

DRAWING TITLE:-
DETAILS FOR SWIMMING POOL
BASE SLAB AND WALLS

LAKHLANI ASSOCIATES
CIVIL AND STRUCTURAL ENGINEERS

SHREE SOCIETY MAIN ROAD
Nr. SURYAMUKHI HANUMAN TEMPLE
NANA MAVA MAIN ROAD
NEXT TO VIVEKANAND SCHOOL
RAJKOT - 360 001
PHONE : +91 281 247 51 60
E-mail : contact@lakhilani.com
Web : www.lakhilani.com